RADSYNCH 2023 ESRF, 30 May – 2 June 2023

Decommissioning of the ESRF storage ring Paul Berkvens, Patrick Colomp





The European Synchrotron

- 1. Decommissioning of old storage ring
- 2. Update of waste management program: procedures for handling activated components during EBS operation





Replacement of storage ring:

- All accelerator components, except ID vessel and IDs and last module of front ends.
- Cable trays and cables.
- Piping.





Recall:

After several years of discussion, the proposal from ESRF for the classification of the dismantled storage ring components as non-activated waste was accepted by the French Nuclear Safety Authority.

The valorisation of these components as non-activated waste was possible after detailed radiation measurements of all individual elements.



Detailed FLUKA study: Only a limited number of elements (injection zone + scrapers) should be considered as activated.

\rightarrow Radioactive zoning

→ All special elements, considered as spare parts.

Surface dose measurements (indistinguishable form background)



guaranteed for 1 cm³ hotspots.







The second

Radsynch 2023 - 1 June 2023 - Decommissioning of the ESRF storage ring - P. Berkvens



Total surface: 1500 m²







Quadrupole / sextupole girder



Putting barcodes on individual components







Part of quadrupole yokes to ESRF11



The European Synchrotron



Disassembled storage ring components, April 2019

Robotised measurements of accelerator components in the ESRF-12 building







Radsynch 2023 – 1 June 2023 - Decommissioning of the ESRF storage ring – P. Berkvens

Detailed measurement protocols archived

Detailed measurement protocols archived	++ ++ référence chambre : CFU124-CV11-11
	++ ++
	mesure 1
- Compte rendu de mesure de classification radiologique dans le cadre du démantèlement de l'anneau de stockage	1 - 2022 07_05_09-58-45 : 54.95860 2 - 2022_07_05_09-58-46 : 59.65770
CHAMBRES A VIDE	3 - 2022_07_05_09-58-47 : 58.25540 4 - 2022_07_05_09-58-48 : 56.48300 5 - 2022_07_05_09-58-49 : 58.33730 6 - 2012_07_05_09-58-49 : 58.33730
Référence: ESRF/SG/RP/CR/decomm1/vacves/2022-1fr, 07/01/2022	7 - 2022_07_05_09-58-50 : 51.7500 8 - 2022_07_05_09-58-51 : 51.97150 8 - 2022_07_05_09-58-52 : 50.34140
Mesures effectuées par : P. Berkvens / P. Colomp Date des mesures : 05/07/2022	9 - 2022_07_05_09-58-53 : 58.24470 10 - 2022_07_05_09-58-54 : 54.16670 11 - 2022_07_05_09-58-55 : 56.70060 12 - 2022_07_05_09-58-55 : 51.36340
Note: les différentes mesures correspondent au protocole pour les chambres à vide, comme décrit dans la section 5.1.2.2 de la référence ESRF/SG/RP/ASN/rapport/decomm1/2016-fr.	13 - 2022_07_05_09-58-57 : 54.67730 14 - 2022_07_05_09-58-58 : 53.13520 15 - 2022_07_05_09-58-59 : 56.85650 16 - 2022_07_05_00-58-59 : 56.85650
+	17 - 2022_07_05_09-59-01 : 52.43810 18 - 2022_07_05_09-59-21 : 54.05490 19 - 2022_07_05_09-59-03 : 54.05490
+	20 - 2022_07_05_09-59-04 : 59.32460 21 - 2022_07_05_09-59-05 : 55.65970 22 - 2022_07_05_09-59-06 : 51.73390
2 - 2022_07_05_09-43-50 : 52.64630 3 - 2022_07_05_09-43-50 : 52.64630 4 - 2022_07_05_09-43-51 : 55.43870 - 2022_07_05_09-43-51 : 55.43870	25 - 2022_07_05_09-59-07 : 56.15090 24 - 2022_07_05_09-59-08 : 55.39430 25 - 2022_07_05_09-59-09 : 57.39440
5 - 2022_07_05_09-26-362; 52.59530 6 - 2022_07_05_09-43-53; 55.80280 7 - 2022_07_05_09-43-54; 56.53180 8 - 307_07_07_06_00-43.55; 56.5080	<pre>mesure 51 brute : cps moyennés sur 1 minute : 55.73359 mesure 51 nette : cps moyennés sur 1 minute : 0.98395 mesure 51 nette / seuil de décision : 0.19</pre>
9 - 2022_07_05_09-43-56 : 55.91370 10 - 2022_07_05_09-43-57 : 57.02560 11 - 2022_07_05_09-43-58 : 57.14700	mesure 52 brute : cps moyennés sur 1 minute : 54.86700 mesure 52 nette : cps moyennés sur 1 minute : 0.11737 mesure 52 nette / seuil de décision : 0.02
17 - 7877 87 82 83-43-53 : 53 /1938	mesure 53 brute : cps moyennés sur 1 minute : 54.41125 mesure 53 nette : cps moyennés sur 1 minute : -0.33839 mesure 52 nette : cpuil de décision : . 0.47
	mesure 55 necte / seul de decision : -0.0/ mesure 54 brute : cps moyennés sur 1 minute : 54.44268
	mesure 54 nette : cps moyennes sur 1 minute : -0.30696 mesure 54 nette / seuil de décision : -0.06
	mesure 55 brute : cps moyennés sur 1 minute : 54.58148 mesure 55 nette : cps moyennés sur 1 minute : -0.16816

| Classification radiologique du composant retenue selon résultats des mesures : non-activée

mesure 55 nette / seuil de décision : -0.03



com	omme décrit dans la section 5.1.2.2 de la référence ESRF/S	G/RP/ASN/rapport/decomm1/2016-fr.
+	+	
mesure	e de bruit de fond	
+	+	
+	+	
1 -	- 2022_07_05_09-43-48 : 54.21200	
2 -	- 2022_07_05_09-43-49 : 52.61850	
3 -	- 2022_07_05_09-43-50 : 52.64630	
4 -	- 2022 07 05 09-43-51 : 55.43870	
5 -	- 2022 07 05 09-43-52 : 52.59530	
6 -	- 2022 07 05 09-43-53 : 55.82820	
7 -	- 2022 07 05 09-43-54 : 56.53180	
8 -	- 2022 07 05 09-43-55 : 53.50080	
9 -	- 2022 07 05 09-43-56 : 56.91370	
10 -	- 2022 07 05 09-43-57 : 57.02560	
11 -	- 2022 07 05 09-43-58 : 57.14700	

All components taken out of the tunnel during the long shutdown have been measured (end 2022).

None of the scanned components showed any measureable level of activation.

More than 1000 tons of metal have been evacuated so far.

The corresponding cumulative net income from the valorisation of this waste is 882 k€.



ESRF-13 building, October 2022: Only ID vacuum vessels are left to be measured.





Throughout the lifetime of the old storage ring, a large number of components were taken out of the tunnel and were stored on site.

All these components are measured and disposed of using the same protocols.



ESRF-12 building, October 2022: part of the storage ring components that were accumulated over the 30 years of operation of the old storage ring.



Request from French Nuclear Safety Authority (ASN):

Provide activation calculations for all accelerators to update the ESRF waste management plan.

The results are used to define waste management zoning in the tunnels and define corresponding procedures to be followed for the verification of the non-activation of accelerator components taken out of the tunnel (simple measurements using hand-held monitors or measurements using ESRF-12 robot).

The procedures do not cover the final decommissioning of the accelerators.

Already done:

- Storage ring
- Booster, standard cells and extraction zone

To be done:

- o Booster injection zone
- o Linac
- o Transfer lines











ESRF



forced entry: 0.78 μ Sv in one h \rightarrow repeat every two hours, 200 h /month \rightarrow 78 μ Sv per month "normal" entry: 0.35 μ Sv in 45 minutes \rightarrow repeat every hour, 200 h /month \rightarrow 70 μ Sv per month 20 days next to collimator (1 month shutdown) \rightarrow < 6 μ Sv

Maximum dose, under completely unrealistic conditions < 80 mSv / month \rightarrow no need for a radiation area.

The European Synchrotron



booster standard cell



booster extraction area and stripline area



Annual beam loss assumptions in booster

(recall: maximum annual injected charge in storage ring: 1.2 mC

	Injection in storage ring	R&D booster	Total
Injection (200 MeV)	2.9 mC	2 mC	4.9 mC
Extraction (6 GeV)	0.4 mC	-	0.4 mC
Scraper (1 GeV)	0.1 mC	0.3 mC	0.4 mC
Scraper (6 GeV)	0.1 mC	0.3 mC	0.4 mC
Striplines (1 GeV)	-	0.3 mC	0.3 mC
Elsewhere in booster (1 GeV)	0.1 mC	0.3 mC	0.4 m0
Total	3.6 mC	3.2 mC	6.8 mC

For activation measurements we assume 0.4 mC lost in a single cell.





Radsynch 2023 – 1 June 2023 - Decommissioning of the ESRF storage ring – P. Berkvens





MANY THANKS FOR YOUR ATTENTION



